



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Client: Neema Pre-School Of Orange
237 Scotland Rd
Orange, NJ 07050

APL Order ID Number: 2090199

Collected : 09/07/2022 7:02

Received: 09/07/2022

Contact:

Contact: 09/20/2022 15:00

Client Project: Neema Pre-School of Orange

Customer Service Rep: Tony Tudda

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2090199-01 Drinking Water Room 5 Sink 2 Middle								
Total Metals								
Copper	EPA 200.8	9/8/22 18:43	9/8/22 18:43	0.611			0.00200	mg/L
Lead	EPA 200.8	9/8/22 18:43	9/8/22 18:43	< 0.00200	U		0.00200	mg/L
2090199-02 Drinking Water Room 2 Bathroom 1								
Total Metals								
Copper	EPA 200.8	9/8/22 18:46	9/8/22 18:46	0.584			0.00200	mg/L
Lead	EPA 200.8	9/8/22 18:46	9/8/22 18:46	< 0.00200	U		0.00200	mg/L
2090199-03 Drinking Water Kitchen Sink								
Total Metals								
Copper	EPA 200.8	9/8/22 18:48	9/8/22 18:48	0.375			0.00200	mg/L
Lead	EPA 200.8	9/8/22 18:48	9/8/22 18:48	< 0.00200	U		0.00200	mg/L
2090199-04 Drinking Water Room 5 Sink 1 From Family Office								
Total Metals								
Copper	EPA 200.8	9/8/22 18:51	9/8/22 18:51	0.656			0.00200	mg/L
Lead	EPA 200.8	9/8/22 18:51	9/8/22 18:51	< 0.00200	U		0.00200	mg/L
2090199-05 Drinking Water Room 2 Bathroom 2								
Total Metals								
Copper	EPA 200.8	9/8/22 18:53	9/8/22 18:53	0.442			0.00200	mg/L
Lead	EPA 200.8	9/8/22 18:53	9/8/22 18:53	< 0.00200	U		0.00200	mg/L

Brian Wood
Laboratory Director

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
--------------------------	--------	----------	----------	--------	------	-----	----	-------

2090199-06 Drinking Water Room 5 Sink 3 Next To Room 4

Total Metals


Copper	EPA 200.8	9/8/22 18:56	9/8/22 18:56	0.523			0.00200	mg/L
Lead	EPA 200.8	9/8/22 18:56	9/8/22 18:56	< 0.00200	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)

Brian Wood
Laboratory Director





2021-2022 Testing for Lead in School Drinking Water Statement of Assurance (SOA)



Thanks!

Your SOA for the 2021-22 Water Lead Testing Program has been successfully submitted.

Please note:

- **Click the button below to print or obtain a PDF of the submitted SOA before exiting the SOA webpage. There are no other opportunities to print or download responses.**
- The Department will only contact entity representatives if its review of the submitted SOA finds compliance issues.
- A SOA status list of the reporting entities can be found on the Department's Testing for Lead in School Drinking Water webpage at <https://www.nj.gov/education/lead/>. Please note the date the list was updated when reviewing.
- If a submitted application requires updating during the reporting period, a second SOA can be submitted and will replace the original submission. The Department will not keep a record of the original submission.
- An approved SOA is required for State reimbursement for water testing. See <https://www.nj.gov/education/lead/> for information concerning the reimbursement process.
- Questions can be emailed to leadtesting@doe.nj.gov.